


# 耐熱電線電纜(HR-CV):



電纜構造:

- 導體：軟銅單線或軟銅絞線
- 絕緣：交連聚乙烯(XLPE)材質
- 絞合：(多芯適用)
- 繃紮帶：必要時
- 被覆：聚氯乙烯(PVC)材質

參考規範: 消防署--耐熱電線電纜認可基準

## 耐熱電線電纜(HR-CV)

標稱電壓：600V 以下使用範圍

芯數	導體			絕緣厚度 mm	被覆厚度 mm	最導體電阻 Ω/km (20°C)	試驗電壓 kV/分	最絕緣電阻 MΩ.km (20°C)	完成外徑 mm (約)	芯數	導體			絕緣厚度 mm	被覆厚度 mm	最導體電阻 Ω/km (20°C)	試驗電壓 kV/分	最絕緣電阻 MΩ.km (20°C)	完成外徑 mm (約)
	規格	構成	外徑 mm								規格	構成	外徑 mm						
1	0.65 mm	1/0.65	0.65	0.4	0.8	53.0	1.5/1	50	3.1	1	1.6 mm	1/1.6	1.6	0.5	0.8	9.01	1.5/1	50	4.2
2					1.0	53.0			4.9	2					1.0	9.01			7.2
3					1.0	53.0			5.1	3					1.0	9.01			7.6
4					1.0	53.0			5.5	4					1.0	9.01			8.3
7					1.0	53.0			6.4	7					1.0	9.01			9.8
10					1.0	53.0			7.8	10					1.0	9.01			12.4
12					1.0	53.0			8.0	12					1.0	9.01			12.8
24					1.0	53.0			10.7	24					1.0	9.01			18.2
30					1.0	53.0			11.3	30					1.0	9.01			19.3
1					0.9 mm	1/0.9			0.9	0.4					0.8	28.5			1.5/1
2	1.0	28.5	5.4	2			1.0	5.77			8.0								
3	1.0	28.5	5.7	3			1.0	5.77			8.5								
4	1.0	28.5	6.1	4			1.0	5.77			9.2								
7	1.0	28.5	7.1	7			1.0	5.77			11.0								
10	1.0	28.5	8.8	10			1.0	5.77			14.0								
12	1.0	28.5	9.1	12			1.0	5.77			14.5								
24	1.0	28.5	12.2	24			1.0	5.77			20.6								
30	1.0	28.5	12.9	30			1.0	5.77			21.8								
1	1.0 mm	1/1.0	1.0	0.5			0.8	23.1			1.5/1	50	3.6	1	1.25 mm <sup>2</sup>	7/0.45	1.35	0.5	
2					1.0	23.1	6.0	2	1.0	16.8			6.7						
3					1.0	23.1	6.3	3	1.0	16.8			7.1						
4					1.0	23.1	6.8	4	1.0	16.8			7.7						
7					1.0	23.1	8.0	7	1.0	16.8			9.1						
10					1.0	23.1	10.0	10	1.0	16.8			11.4						
12					1.0	23.1	10.3	12	1.0	16.8			11.8						
24					1.0	23.1	14.0	24	1.0	16.8			16.3						
30					1.1	23.1	15.0	30	1.1	16.8			17.3						
1					1.2 mm	1/1.2	1.2	0.5	0.8	16.0			1.5/1	50					3.8
2	1.0	16.0	6.4	2					1.0	9.43	7.6								
3	1.0	16.0	6.7	3					1.0	9.43	8.0								
4	1.0	16.0	7.3	4					1.0	9.43	8.8								
7	1.0	16.0	8.6	7					1.0	9.43	10.4								
10	1.0	16.0	10.8	10					1.0	9.43	13.2								
12	1.0	16.0	11.1	12					1.0	9.43	13.6								
24	1.1	16.0	15.2	24					1.0	9.43	19.4								
30	1.1	16.0	16.3	30					1.4	9.43	20.6								

註:如有爭議悉以消防署耐熱電線電纜認可基準為準



大亞集團

大亞電線電纜

大亞電線電纜股份有限公司

Ta Ya Electric Wire & Cable Co.,Ltd.